



Institut de Sécurité Incendie asbl
Instituut voor Brandveiligheid vzw
ISIB
Rue Belvaux 87, B - 4030 LIÈGE



CERTIFICATE OF CONSTANCY OF PERFORMANCE

2694 – CPR – 16034-17003-01

In compliance with *Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

External pedestrian doorsets “Heinen EI₂ 120”

External pedestrian doorsets with fire resisting and/or smoke control characteristics

Placed on the market under the name or trade mark of:

**HEINEN SA
Rue derrière l' eau 11
4960 MALMÉDY
BELGIUM**

and produced in the manufacturing plant:

**HEINEN SA
Rondthier
4960 MALMÉDY
BELGIUM**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 14351-1:2006+A2:2016

and

EN 16034:2014

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 21/12/2017 and will remain valid until 21/12/2022 as long as neither the harmonised standards, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Date of issue : 21/12/2017

dr. ir. Bart SETTE
President



190-PROD

The validity of this certificate may be confirmed at the web address www.isibfire.be

CERTIFICATE OF CONSTANCY OF PERFORMANCE

2694 – CPR – 16034-17003-01

Annex (2 pages)

External pedestrian doorsets
Heinen EI₂ 120
Performances according to Annex ZA of EN 16034
Resistance to fire: EI ₂ 120, EW 120, EI ₁ 60: Field of application: see table underneath
Smoke control: npd
Ability to release: npd
Self-closing: npd (without closing device), C (with closing device)
Durability of ability to release: npd
Durability of self-closing: <ul style="list-style-type: none">• against degradation (cycling testing): C5 (with closing device)• against ageing (corrosion): npd

CERTIFICATE OF CONSTANCY OF PERFORMANCE

2694 – CPR – 16034-17003-01

Field of application for resistance to fire

EI₂ 120 / EW 120 / EI₁ 60	
Max. Dimensions door leaf (Width x Height – mm x mm) (Surface – m²)	Min. Dimensions door leaf (Width x Height – mm x mm)
Single leaf door	
1425 x 3035 (3,62 m ²)	570 x 1834
Double leaf door	
1800 x 3035 (4,61 m ²)	281 x 1834 (without glazing) 561 x 1834 (with glazing)
Supporting construction (min. thickness, min.density)	High density rigid wall (140 mm, 1700 kg/m ³) Low density rigid wall (150 mm, 480 kg/m ³)
Infill material	Concrete
Glazing	AGC Pyrobel 53 N max. dimensions: 525 mm x 525 mm min. distance to edge of door leaf: 188 mm

End of document